



Jim Doyle, Governor Mary P. Burke, Secretary

December 20, 2004

WIESER CONCRETE PRODUCTS, INC. MARK WIESER 2815 RILEY ROAD PORTAGE WI 53901

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)

Manufacturer: WIESER CONCRETE PRODUCTS, INC.

Product Name: BIO-MICROBICS MIROFAST 9.0

Model Number(s): W9000 Product File No: 20040604

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2009.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This tank may only be installed in conjunction with the Bio-Microbics Inc., sewage treatment apparatus.
- 1. A copy of this approval letter must be supplied to the buyer and installer of each tank sold.
 - 2. All laitance, loose or foreign material must be removed from each joint surface prior to the sealant being applied.
 - 3. Continuous sealant meeting Federal Specification SS-S-00210-A must be applied to each tongue and groove wall joint.
 - 4. After placement of the concrete sections on the sealant, continuous squeeze-out of the sealant must be visible inside and outside the tank.
 - 5. A certified plumbing inspector must confirm compliance with limitations 2, 3 and 4 above, by direct observations during each process.
- This product must be installed in accordance with the manufacturer's printed instructions, product approval and
 the plan approval. If there is a conflict between the manufacturer's instructions and the plan approval, the plan
 approval will take precedence.
- The maximum daily wastewater flow which may discharge through this product is 9000 gallons per day.

This approval supersedes the approval issued on INSERT DATE under product file number 20000139.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20000139

SBD-10564-E (N.10/97) File Ref: 04060401.DOC

WIESER CONCRETE PRODUCTS, INC. Page 2 December 20, 2004

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE Plumbing Product Reviewer phone: 608-266-6742

fax: 608-267-9566

e-mail: mike.beckwith@wisconsin.gov